

PROJECT: HULA/18164 GROUP: NEW Permit Site Photometr AREA: 44 South Entry GRID: Ground
 PREPARED BY:
 VALUES ARE FC, SCALE: 1 IN= 8.0FT, HORZ GRID (U), HORZ CALC, Z= 0.0

Computed in accordance with IES recommendations

Statistics

GROUP	MIN	MAX	AVE	AVE/MIN	MAX/MIN
(+)	0.46	7.13	4.31	9.45	15.62

Luminaires Used

TYPE	QTY	TEST#	DESCRIPTION
C	2	LC6SL_6L	PRESCOLITE, LC6SL 6LCSL10L35K8, 6" LED Downlight, 3500K, 3 SDC, LAMPS: (1) NFSL757GT-V1, 1071 LUMENS, BLST: LED25W-36-C0700, LLF = 0.90 @11.00
G	1	rab02318	RAB LIGHTING IN, WPLED10N (WALLPACK) - ALED10N (AREA LIGHTER) - BLE, CAST METAL HOUSING, ONE CIRCUIT, REFLECTOR WITH SEMI-DIFFUSE FI LAMPS: (1) , 1252 LUMENS, BLST: , LLF = 0.90 @13.00

