

PROJECT: HULA/18164 GROUP: NEW Permit Site Photometr AREA: 50 East Entry GRID: Ground
 PREPARED BY:
 VALUES ARE FC, SCALE: 1 IN= 2.0FT, HORZ GRID (U), HORZ CALC, Z= 0.0

Computed in accordance with IES recommendations

Statistics

GROUP	MIN	MAX	AVE	AVE/MIN	MAX/MIN
(+)	3.64	8.41	6.55	1.80	2.31

Luminaires Used

TYPE	QTY	TEST#	DESCRIPTION
C	1	LC6SL_6L	PRESCOLITE, LC6SL 6LCSL10L35K8, 6" LED Downlight, 3500K, 3 SDC, LAMPS: (1) NFSL757GT-V1, 1071 LUMENS, BLST: LED25W-36-C0700, LLF = 0.90 @9.00

Y-AXIS

