

PROJECT: HULA/18164 GROUP: NEW Permit Site Photometr AREA: 50 North Walk GRID: Ground
PREPARED BY:
VALUES ARE FC, SCALE: 1 IN=4.0FT, HORZ GRID (U), HORZ CALC, Z=0.0

Computed in accordance with IES recommendations

GROUP	MIN	MAX	AVE	AVE/MIN	MAX/MIN
(*)	0.15	10.31	2.65	17.70	68.79

Luminaires Used

TYPE	QTY	TEST#	DESCRIPTION
C	2	LC6SL_6L	PRESCOLITE, LC6SL 6LCSL10L35K8, 6" LED Downlight, 3500K, 3 SDG, LAMPS: (1) NFSL757GT-V1, 1071 LUMENS, BLST, LED25W-36-C0700, LLF = 0.90 @11.00
F3	1	ALED3T50	RAB LIGHTING IN, ALED3T50N - RWLED3T50N - RWLED3T50SFN - WPLED3T50N, CAST FINNED METAL HOUSING, 6 C, LED, MOLDED PLASTIC REFLECTOR LAMPS: (6), 6522 LUMENS, BLST, LLF = 0.90 @20.00
G	2	ra020318	RAB LIGHTING IN, WPLED10N (WALLPACK) - ALED10N (AREA LIGHTER) - BLE, CAST METAL HOUSING, ONE CIRCUL REFLECTOR WITH SEMI-DIFFUSE FI LAMPS: (1), 1252 LUMENS, BLST, LLF = 0.90 @13.00
H2	1	303-B1-L	EATON - LUMIERE, 303-B1-LEDB1-4000-UNV-T2-DIM10-BK, LUMIERE EON 303-B1, SINGLE HEA, TEST IS SCALED FROM IESNA LM-7 LAMPS: (7), 677 LUMENS, BLST, LLF = 0.90 @3.50
H4	5	303-B1-L	EATON - LUMIERE, 303-B1-LEDB1-4000-UNV-T4-DIM10-BK, LUMIERE EON 303-B1, SINGLE HEA, TEST IS SCALED FROM IESNA LM-7 LAMPS: (7), 646 LUMENS, BLST, LLF = 0.90 @3.50

