

PROJECT: HULA/18164 GROUP: NEW Permit Site Photometr AREA: 50 South Entry GRID: Ground
 PREPARED BY:
 VALUES ARE FC, SCALE: 1 IN= 4.0FT, HORZ GRID (U), HORZ CALC, Z= 0.0

Computed in accordance with IES recommendations

Statistics

| GROUP | MIN | MAX | AVE | AVE/MIN | MAX/MIN |
|-------|------|------|------|---------|---------|
| (+) | 0.38 | 8.08 | 4.12 | 10.76 | 21.08 |

Luminaires Used

| TYPE | QTY | TEST# | DESCRIPTION |
|------|-----|----------|---|
| C | 2 | LC6SL_6L | PRESCOLITE, LC6SL 6LCSL10L35K8, 6" LED Downlight, 3500K, 3 SDC, LAMPS: (1) NFSL757GT-V1, 1071 LUMENS, BLST: LED25W-36-C0700, LLF = 0.90 @11.00 |

